



BODY ART FACILITY PLAN REVIEW

Facility Requirements

- 1.1. All body art facilities shall be completely separated by solid partitions or by walls extending from floor to ceiling, from any room used for human habitation or any activity that may cause potential contamination of work surfaces.
- 1.2. The body art facility shall have self-closing doors and windows equipped with screens in good repair if the windows are intended to be used for ventilation.
- 1.3. Body art procedure areas shall be separated from the customer waiting area/retail area by a panel or wall at least four feet high.
- 1.4. There shall be a minimum of 45 square feet of floor space for each body art technician's body art procedure area in the facility.
- 1.5. All walls and floors of a body art facility shall be smooth, free of open holes or cracks, washable and in good repair. Walls, floors and ceilings shall be maintained in a clean condition.
- 1.6. All procedure surfaces in the body art procedure area, including client chairs, tables, benches, and counters shall be smooth, free of open holes or cracks, washable and in good repair. All procedure surfaces, including client chairs, tables, benches, and counters shall be of such construction as to be easily cleaned and disinfected after each use/between clients.
- 1.7. The facility shall be well-ventilated and provided with an artificial light source equivalent to at least 20 foot candles three feet off the floor, except that 100 foot candles shall be provided at the level where the body art procedures are being performed, and where instruments and sharps are handled/assembled. Spot lighting may be utilized to achieve this required degree of illumination for the purpose of conducting body art procedures.
- 1.8. A separate, hand washing facility comprised of a sink with warm running, water under pressure, preferably equipped with wrist or foot-operated controls and supplied with liquid soap and disposable paper towels shall be readily accessible within the body art facility. There shall be a covered waste receptacle by each sink for the disposal of paper towels. One hand sink shall serve no more than three body art technicians.
- 1.9. There shall be a minimum of one lavatory with a toilet and a separate sink in a body art facility.

- 1.10. A body art facility shall have a separate room or area for the sole purpose of cleaning, disinfecting and sterilizing. This area shall be separated from the remainder of the facility by a minimum of a wall or partition and shall be an area that does not allow client access. The cleaning, disinfecting, and sterilizing area shall be organized to prevent cross-contamination of clean, disinfected or sterile equipment with dirty equipment.
- 1.11. All sinks in the body art facility shall only be used for their designated purpose.
- 1.12. All chemical or cleaning supply containers shall be properly labeled.
- 1.13. At least one covered waste receptacle shall be provided in each body art procedure area and each toilet room. Each receptacle shall have a lid and the lid shall be kept closed at all times. Waste receptacles in the body art procedure area(s) shall be emptied daily and solid waste shall be removed from the premises at least weekly. All waste receptacles shall be cleanable and kept clean, and capable of being disinfected.
- 1.14. Sharps disposal containers shall be made available at places as close as feasibly possible to any area where needles and sharps are used.
 - 1.14.1. These containers must be hard, puncture-resistant, leak-proof containers specifically designed for the storage of sharps.
 - 1.14.2. They must be labeled with the universal biohazard symbol or color-coded.
 - 1.14.3. They must be maintained in an upright position, and replaced frequently to avoid over-filling.
 - 1.14.4. When moving sharps' containers, the containers must be closed. If leakage is possible, they must be placed in a second container that will contain all contents, prevent leakage, and labeled with the universal biohazard symbol or be color-coded.
 - 1.14.5. Sharps' containers must be changed, at a minimum, 90 days after the date of first use.
- 1.15. No animals of any kind shall be allowed in the body art facility except service animals used by persons with disabilities (e.g., seeing-eye dogs). Fish aquariums shall be allowed in waiting rooms and non-procedural areas.

1.16. Effective measures shall be taken by the owner or operator of the body art facility to protect against entrance into the facility and against the breeding or presence on the premises of insects, vermin, and rodents. Insects, vermin, and rodents shall not be present in any parts of the Facility.

1.17. For new body art facilities and for body art facilities undergoing renovation, an 8 ½ X 11 or larger scale drawing and floor plan of the proposed facility or the proposed renovation of the facility shall be submitted to the local health department responsible for body art facility inspection for the jurisdiction in which the body art facility will be/is located. This drawing shall show the accurate placement of each of the following items: walls, windows, doors, waiting area, procedure area(s), bathroom(s), cleaning, disinfection, and sterilization area, equipment/instrument storage area(s) chairs, tables, and sinks. This scale drawing and floor plan shall be submitted at least 60 days before the proposed opening/planned renovation. A pre-opening inspection of the premises will be required before body art services can be performed in this new facility/renovated area.

1.18. Requirements for Body Art Facilities does not relieve the owner/operator of a licensed body art facility from the responsibility for securing a local permit or complying with applicable local codes, regulations, or ordinances that are in addition to the Requirements for Body Art Facilities.

1.18.1. Water supply; plumbing.

(1) The water system shall comply with the requirements of the local health authority.


(2) Plumbing shall be designed, constructed, installed, and maintained to prevent cross-connection with the water system.

(3) Sinks, lavatories, drinking fountains, and other water outlets shall be supplied with safe water, sufficient in quantity and pressure, to meet conditions of peak demand.

1.18.2. Sewage disposal.

(1) Sewage and other water-carried wastes shall be disposed of through a municipal or private sewer system.

(2) Private sewer/septic systems shall be designed and operated to safely dispose of all wastewater generated, shall



BODY ART FACILITY FLOOR PLAN & EQUIPMENT LAYOUT Scale $\frac{1}{4}$ " = 1 foot
(If other scale, notify: _____)

BODY ART FACILITY _____.

Submitted by: _____ Date: _____